

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ322		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PETERSON, RALPH						Phone # () 536-8950		1. Well Location				Fire # (if avail.)	
Mailing Address W4550 HWY G						Town of MERRILL							
City MERRILL						State WI		Zip Code 54452					
County Lincoln		Co. Permit #		Notification #		Completed 10-14-1998		Street Address or Road Name and Number SMITH AVE					
								Subdivision Name				Lot # Block #	
Well Constructor (Business Name) JAMES A HORNUNG SR				Lic. # 695		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address W4014 ALPINE AVE MERRILL WI 54452-9064				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NE Section Township Range or Govt Lot # 5 31 N 7 E					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) 6		From (ft.) Surface		To (ft.) 100		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) Y U SAND & GRAVEL MUDDY Surface 70 D Q C CLAY DECOMPOSED GRANITE 70 90 G Q GRANITE GRAY 90 100			
6. Casing, Liner, Screen													
Dia. (in.) 6		Material, Weight, Specification SAWHILL BLACK WELDED ASTMA53B				From (ft.) Surface		To (ft.) 76		9. Static Water Level			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										25 ft. below ground surface 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.) Surface		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE					
13. Constructor / Supervisory Driller													
JH		Lic #		Date Signed 10-14-1998									
Drill Rig Operator		Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		40	Foundation Drain to Clearwater		30
Building Overhang		30	Sewer - Building Sanitary		50
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 12-06-1999

Updated On: 12-06-1999

Review Status: