Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MQ543

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CLOVER, MICHAEL	Phone #: (715)834-7700
Mailing Address: 2108 DANIELS AVE	
City: EAU CLAIRE	State: WI — Zip Code: 54720
County: Eau Claire	Co. Permit #: W15411 — Notification # — Completed: 10-26-1998
Well Constructor (Business Name): OLSON KEN WELL DRLG @ PUMP SER I	Lic. #: 215 — Facility ID # (Public Wells)
Address: 10224 20TH AVE EAU CLAIRE WI 54703-0288	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 1.4

1. Well Location

Town of WASHINGTON

Fire # (if avail.)

Street Address or Road Name and Number: 1301 SANDY RIDGE LN

Subdivision Name: CSM 1511	Lot #: 2	Block #

Latitude / Longitude in Decimal Degree (DD): 44.8055 °N -91.4039 °W	Method Code: GCD013			
NW SW or Govt Lot #	Section: 19	Township: 27 N	Range: 8 W	

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	107

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	33
		Z		GRAVEL @ CLAY	33	39
		X		SAND @ CLAY	39	48
	S	N		SOFT SANDSTONE	48	56
	M	N		MEDIUM SANDSTONE	56	107

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL NEW BLACK T@C ASTM A53 280 WALL 19 45# FTSAWHILL @ IPSCO	Surface	71
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

61 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 20 GP M for 1.5 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DKO		10-26-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Drain - Sanitary		23
Building Overhang		9
Sewer - Building Sanitary		50
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 11-24-1998 Updated On: 08-01-2019 Review Status: