

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ558		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WELKE, RUSSELL						Phone # (715)723-3349		1. Well Location				Fire # (if avail.)			
Mailing Address 18401 70TH AVE						Town of LAFAYETTE						18401			
City CHIPPEWA FALLS						State WI		Zip Code 54729				Street Address or Road Name and Number 18401 70TH AVE			
County Chippewa		Co. Permit # W16201		Notification #		Completed 10-22-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) OLSON KEN WELL DRLG @ PUMP SER I				Lic. # 215		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9438 °N -91.2989 °W				Method Code GCD013	
Address 10224 20TH AVE EAU CLAIRE WI 54703-0288				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 1 28 N 8 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? PUMP BROKE OFF IN OLD WEL							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		Construction Type Drilled									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method						8. Geology									
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
6 Surface 74		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				I TOPSOIL Surface 1 S SAND 1 20 Y SAND @ GRAVEL 20 74									
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		37 ft. below ground surface		14 in. above grade					
6		STEEL T@C NEW BLACK 19 45# PER FT 280 WALL ASTMA53SAWHILL @ IPSCO				Surface 71		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 48 ft. below surface Pumping at 12 GP M for 3 Hrs. Pumping Method ?							
5		15 SLOT JOHNSON STAINLESS				71 74									
7. Grout or Other Sealing Material Method						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No OWNER TO COMPLY									
						13. Constructor / Supervisory Driller		Lic #		Date Signed					
						KDO				10-22-1998					
						Drill Rig Operator		Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		130	Buried Petroleum Tank		115
Building Drain - Sanitary		80	Sewer - Building Sanitary		90
Building Overhang		30	Septic or Holding, or POWTS Tank		115

Comment:

Created On: 11-24-1998

Updated On: 06-11-2020

Review Status: