Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MQ833

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUSSE, DAN	Phone #: (608)546-2070
Mailing Address: S10271 SUNNY LN	
City: SPRING GREEN	State: WI — Zip Code: 53588
County: Sauk	Co. Permit #:
Notification #	Completed: 10-29-1998
Well Constructor (Business Name): RICHARD BERKHOLTZ	Lic. #: 3
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 6400 LAKE RD WINDSOR WI 53598-9717	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.1	

1. Well Location

Town of FRANKLIN

Fire # (if avail.)

Street Address or Road Name and Number: COUNTY HWY B

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE NW or Govt Lot #	Section	Township	Range
	7	9 N	4 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW CONSTRUCTION

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	61
6	61	305

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	6
T		N		TAN SANDSTONE	6	125
E		N		GREEN SANDSTONE	125	141
I		N		WHITE SANDSTONE	141	225
T		N		BROWN SANDSTONE	225	305

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD STEEL PE 18 97 LBS ASTM A53 SAWHILL	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRAIDENHEAD BENTONITE CIRCULAT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	61	28 S

9. Static Water Level

170 ft. below ground surface

10. Pump Test

Pumping level 240 ft. below surface

Pumping at 10 GP M for 0.25 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		10-30-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RCB		10-30-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	120

Type	Qualifier	Distance
Building Overhang		15
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-15-1999 Updated On: 01-15-1999 Review Status: