

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ835		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner FOX, STEVE						Phone # (815)943-8328		1. Well Location				Fire # (if avail.)									
Mailing Address 18707 LINCOLN RD						Town of PERRY						Street Address or Road Name and Number									
City HARVARD						State IL		Zip Code 60033				10626 COUNTY A									
County Dane		Co. Permit # W15864		Notification #		Completed 11-03-1998		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) RICHARD BERKHOLTZ				Lic. # 3		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.9118 °N -89.8017 °W				Method Code GCD013							
Address 6400 LAKE RD WINDSOR WI 53598-9717				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 17 5 N 6 E				2. Well Type New Well											
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ? NEW CONSTRUCTION				Construction Type Drilled											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Hicap Potable ?											
Heat Exchange ___ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		62		Rotary - Mud Circulation						C		CLAY		Surface		6			
6		62		205		Yes Rotary - Air				T		N		TAN SANDSTONE		6		145			
						Rotary - Air & Foam						N		RED @ WHITE SANDSTONE		145		175			
						Drill-Through Casing Hammer						B		N		BROKEN SANDSTONE		175		185	
						Reverse Rotary						N		RED @ WHITE SANDSTONE		185		205			
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		100 ft. below ground surface				12 in. above grade							
6		STD STEEL PE 18 97 ASTM A53 SAWHILL				Surface		62		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 165 ft. below surface				Disinfected ? Yes							
										Pumping at 20 GP M for 0.25 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?									
Method BRAIDEN HEAD BENTONITE CIRCULA												Filled & Sealed Well(s) as needed?									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
NEAT CEMENT		Surface		62		12 S															
												NONE									
13. Constructor / Supervisory Driller								Lic #		Date Signed											
RB										11-04-1998											
Drill Rig Operator								Lic or Reg #		Date Signed											
RCB										11-04-1998											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	15	Septic or Holding, or POWTS Tank	>	40
			POWTS dispersal component (soil absorption unit or mound)	>	80

Comment:

Created On: 11-24-1998

Updated On: 12-11-2019

Review Status: