Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MQ835

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FOX, STEVE	Phone #: (815)943-8328
Mailing Address: 18707 LINCOLN RD	
City: HARVARD	State: IL — Zip Code: 60033
County: Dane	Co. Permit #: W15864 — Notification # — Completed: 11-03-1998
Well Constructor (Business Name): RICHARD BERKHOLTZ	Lic. #: 3 — Facility ID # (Public Wells)
Address: 6400 LAKE RD, WINDSOR WI 53598-9717	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.3

1. Well Location

Town of PERRY

Fire # (if avail.)

Street Address or Road Name and Number: 10626 COUNTY A

Subdivision Name — Lot # — Block #

Latitude / Longitude in Decimal Degree (DD): 42.9118 °N -89.8017 °W — Method Code: GCD013

SE NE or Govt Lot # — Section: 17 — Township: 5 N — Range: 6 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NEW CONSTRUCTION

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6	62	205

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	6
T		N		TAN SANDSTONE	6	145
		N		RED @ WHITE SANDSTONE	145	175
	B	N		BROKEN SANDSTONE	175	185
		N		RED @ WHITE SANDSTONE	185	205

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD STEEL PE 18 97 ASTM A53 SAWHILL	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

100 ft. below ground surface

10. Pump Test

Pumping level 165 ft. below surface

Pumping at 20 GP M for 0.25 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRAIDEN HEAD BENTONITE CIRCULA

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	62	12 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		11-04-1998
Drill Rig Operator	Lic or Reg #	Date Signed
RCB		11-04-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	80

Type	Qualifier	Distance
Building Overhang	>	15
Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 11-24-1998 Updated On: 12-11-2019 Review Status: