

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ940		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KNAPP, TOM						Phone # (715)325-6508		1. Well Location				Fire # (if avail.)					
Mailing Address 611 DEER RUN RD						Town of ROME						611					
City NEKOOSA						State WI		Zip Code 54457				Street Address or Road Name and Number 611 DEER RUN RD					
County Adams		Co. Permit #		Notification #		Completed 10-20-1998		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) HAUPT WELL @ PUMP CO INC				Lic. # 529		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1682 °N -89.8901 °W				Method Code GCD013			
Address 5508 MAIN ST AUBURNDALE WI 54412				Well Plan Approval # Approval Date (mm-dd-yyyy)		NE NW		Section 34		Township 20 N		Range 5 E					
						or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 10				2. Well Type Replacement of previous unique well # constructed in							
Reason for replaced or reconstructed well ? QUANTITY																	
3. Well serves 1 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method														8. Geology			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		56.6													
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						S		SAND		Surface		9					
						C S		SANDY CLAY		9		14					
						C		CLAY		14		46					
						M S		MEDIUM SAND		46		56.6					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		33 ft. below ground surface 18 in. above grade							
6		STEEL 18 97 A53 SAWHILL PE WELDED				Surface		53.6		10. Pump Test Pumping level 36 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ?							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes							
5		TELE US FILTER SS #12				53.6		56.6									
7. Grout or Other Sealing Material Method MOUND						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NOT YET											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
#8		Surface		0		1 S											
						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						DH						10-21-1998					
						Drill Rig Operator				Lic or Reg #		Date Signed					
						AH						10-21-1998					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		64	Building Overhang		5
			Septic or Holding, or POWTS Tank		34

Comment:

Created On: 11-18-1998

Updated On: 05-04-2020

Review Status: