

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ941		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner WORMET, GREG						Phone # (715)325-2604		1. Well Location				Fire # (if avail.)	
Mailing Address 9230 CTH Z						Town of SARATOGA						Street Address or Road Name and Number 9230 Z	
City NEKOOSA				State WI		Zip Code 54457		Subdivision Name				Lot # Block #	
County Wood		Co. Permit #		Notification #		Completed 10-21-1998		Latitude / Longitude in Decimal Degree (DD) 44.3105 °N -89.8447 °W				Method Code GCD013	
Well Constructor (Business Name) HAUPT WELL @ PUMP CO INC				Lic. # 529		Facility ID # (Public Wells)		SE SE Section Township Range or Govt Lot # 12 21 N 5 E		2. Well Type Replacement			
Address 5508 MAIN ST AUBURNDALE WI 54412				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in					
Hicap Permanent Well #				Common Well #		Specific Capacity 7.5		Reason for replaced or reconstructed well ? QUANTITY					
3. Well serves 0 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		50									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
S			SAND			Surface			21				
C			CLAY			21			36				
N S M			SAND SILTY TO FINE			36			44				
M S			SAND MEDIUM			44			50				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL 18 97 A53 SAWHILL PE WELDED				Surface		47					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		US FILTER #15 SS				47		50					
7. Grout or Other Sealing Material													
Method MOUND													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
#8				Surface		0		1 S					
9. Static Water Level													
32 ft. below ground surface													
10. Pump Test													
Pumping level 36 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ?													
11. Well Is													
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #								Date Signed					
DH								10-23-1998					
Drill Rig Operator								Lic or Reg #					
AH								10-23-1998					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Building Overhang		5
			Septic or Holding, or POWTS Tank		27

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	10/22/1998	CONCRETE TO 25' 1 SACK USED	NO WATER

Created On: 11-17-1998

Updated On: 07-11-2023

Review Status: