

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ942		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LARSON, JAMES						Phone # (715)422-1323		1. Well Location				Fire # (if avail.)	
Mailing Address 4110 WESLAN DR						Town of GRAND RAPIDS						4110	
City WISCONSIN RAPIDS						State WI		Zip Code 54494				Street Address or Road Name and Number 4110 WESLAN	
County Wood		Co. Permit #		Notification #		Completed 10-23-1998		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) HAUPT WELL @ PUMP CO INC				Lic. # 529		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.3501 °N -89.7751 °W				Method Code GCD013	
Address 5508 MAIN ST AUBURNDALE WI 54412				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 34 22 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? QUANTITY Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 6.4									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		46.7						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) S SAND Surface 27 C CLAY 27 28 S SAND 28 46.7			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		STEEL 18 97 A53 SAWHILL PE WELDED				Surface		43.7		32 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test			
5		US FILTER UOP #12 SS				43.7		46.7		Pumping level 37 ft. below surface Pumping at 32 GP M for 1 Hrs. Pumping Method ?			
7. Grout or Other Sealing Material													
Method MOUND													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is					
#8		Surface		0		1 S		15 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
DH										11-06-1998			
Drill Rig Operator								Lic or Reg #		Date Signed			
AH										11-06-1998			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang		8
			Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 01-19-1999

Updated On: 05-05-2020

Review Status: