Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MS047

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TURNER, LINDA	Phone #: (715)484-7603
Mailing Address: 8322 CTH DD	
City: PICKEREL	State: WI Zip Code: 54465
County: Forest	Co. Permit #:
Notification #:	Completed: 12-02-1998
Well Constructor (Business Name): TIPLER WELL DRILLING INC	Lic. #: 55
Facility ID # (Public Wells):	
Address: PO BOX 34 LAKEWOOD WI 54138-0034	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of NASHVILLE

Fire # (if avail.):

Street Address or Road Name and Number: 8322 CTY H DD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 45.40399 °N -88.85418 °W

Method Code: GPS008

NE NW or Govt Lot #: | Section: 27 | Township: 34 N | Range: 13 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: REPLACED SANDPOINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	64

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND GRAVEL	Surface	15
		G	G	GRAVEL BOULDERS	15	30
		Y		SAND GRAVEL	30	64

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 GR B SAWHILL TUBULAR WELDED JOINT WT 18 97 PER FT	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	12 SLOT STAINLEESS SCREEN	59	64

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NOTIFIED TO ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		12-28-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MB		12-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 03-29-1999 Updated On: 08-23-2022 Review Status: