

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MS047		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner TURNER, LINDA						Phone # (715)484-7603		1. Well Location				Fire # (if avail.)			
Mailing Address 8322 CTH DD						Town of NASHVILLE									
City PICKEREL						State WI		Zip Code 54465							
County Forest		Co. Permit #		Notification #		Completed 12-02-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) TIPLER WELL DRILLING INC				Lic. # 55		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.40399 °N -88.85418 °W				Method Code GPS008	
Address PO BOX 34 LAKEWOOD WI 54138-0034				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 27 34 N 13 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? REPLACED SANDPOINT							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 20 64															
8. Geology															
Dia. (in.) From (ft.) To (ft.)			Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)				
			Y				SAND GRAVEL				Surface 15				
			G G				GRAVEL BOULDERS				15 30				
			Y				SAND GRAVEL				30 64				
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		ASTM A53 GR B SAWHILL TUBULAR WELDED JOINT WT 18 97 PER FT				Surface		59							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		12 SLOT STAINLEESS SCREEN				59		64							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
DRILLING MUD				Surface		20									
9. Static Water Level															
20 ft. below ground surface															
10. Pump Test															
Pumping level 46 ft. below surface															
Pumping at 15 GP M for 4 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? NOTIFIED TO ABANDON															
13. Constructor / Supervisory Driller															
AT				Lic #		Date Signed		12-28-1998							
Drill Rig Operator				Lic or Reg #		Date Signed		12-28-1998							
MB															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		10
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 03-29-1999

Updated On: 08-23-2022

Review Status: