Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MS112

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZEKE, MARLENE			Phone #: (920)622-4585
Mailing Address: N4424 STRAWBERRY CIR			
City: WILD ROSE	State: WI	Zip Code: 54984	
County: Waushara	Co. Permit #:	Notification #:	Completed: 11-05-1998

Well Constructor (Business Name): SCHAFER R J @ SONS INC	Lic. #: 177	Facility ID # (Public Wells):	
Address: PO BOX 277 FREMONT WI 54940-0277		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MT MORRIS

Fire # (if avail.): N4424

Street Address or Road Name and Number: N4424 STRAWBERRY CIR

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.1395 °N -89.1836 °W				Method Code: GCD013
NE NW or Govt Lot #	Section: 10	Township: 19 N	Range: 11 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	G	SAND @ STONES	Surface	62
K		G		BLACK BOULDER	62	64
		Y	U	MUDDY SAND @ GRAVEL	64	92
		Y		SAND @ GRAVEL	92	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE NEW STEEL DRILLERS PIPE #18 97 ASTM A 53SAWHILL INDUSTRY	Surface	96
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	X4X12 SLOT STAINLESS STEEL	96	100

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NA	Surface	0	

9. Static Water Level
54 ft. below ground surface

10. Pump Test
Pumping level 79 ft. below surface
Pumping at 25 GP M for 5 Hrs.
Pumping Method ?

11. Well Is
21 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
		11-11-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MAS		11-11-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		61

Type	Qualifier	Distance
Building Overhang		615
Septic or Holding, or POWTS Tank		39

Comment:

Created On: 01-07-1999 Updated On: 05-05-2020 Review Status: