

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MS113		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner HAASE, SHARON						Phone # (920)757-7797		1. Well Location				Fire # (if avail.)									
Mailing Address 249 CHICAGO DR						Town of WARREN						249									
City REDGRANITE						State WI		Zip Code 54970				Street Address or Road Name and Number 249 CHICAGO DR									
County Waushara		Co. Permit #		Notification #		Completed 11-03-1998		Subdivision Name PINE O RAMA SUBD				Lot # 1		Block #							
Well Constructor (Business Name) SCHAFFER R J @ SONS INC				Lic. # 177		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.06262 °N -89.10129 °W				Method Code GPS008							
Address PO BOX 277 FREMONT WI 54940-0277				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 5 18 N 12 E				2. Well Type New Well											
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ? NEW HOME				Construction Type Drilled											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Heat Exchange ___ # of drillholes				Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE												5. Drillhole Dimensions and Construction Method		8. Geology							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 180		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Rotary - Mud Circulation								SAND		Surface		42			
						Rotary - Air								SAND W GRAVEL		42		87			
						Rotary - Air & Foam								SAND		87		123			
						Drill-Through Casing Hammer								MUDDY SAND W CLAY		123		158			
						Reverse Rotary								CLAY		158		172			
						Cable-tool Bit ___ in. dia...								COARSE SAND @ GRAVEL		172		180			
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is											
Dia. (in.) 6		Material, Weight, Specification PE NEW STEEL DRILLERS PIPE #18 97 ASTM A 53SAWHILL INDUSTRY				From (ft.) Surface		To (ft.) 176		93 ft. below ground surface				22 in. above grade							
Dia. (in.) 6		Screen type, material & slot size X4X12 SLOT STAINLESS STEEL				From (ft.) 176		To (ft.) 180		10. Pump Test				Developed ? Yes							
										Pumping level 139 ft. below surface				Disinfected ? Yes							
										Pumping at 25 GP M for 2 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?											
Method																					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement						Filled & Sealed Well(s) as needed?				No					
NA		Surface		0								NONE									
										13. Constructor / Supervisory Driller				Lic #		Date Signed					
																11-19-1908					
						Drill Rig Operator				Lic or Reg #				Date Signed							
						MAS								11-11-1998							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		61	Building Overhang		7
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-07-1999

Updated On: 08-17-2022

Review Status: