Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MS113

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HAASE, SHARON	Phone #: (920)757-7797
Mailing Address: 249 CHICAGO DR	
City: REDGRANITE	State: WI — Zip Code: 54970
County: Waushara	Co. Permit #: — Notification #: — Completed: 11-03-1998
Well Constructor (Business Name): SCHAFER R J @ SONS INC	Lic. #: 177 — Facility ID # (Public Wells):
Address: PO BOX 277, FREMONT WI 54940-0277	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of WARREN				Fire # (if avail.): 249
Street Address or Road Name and Number: 249 CHICAGO DR				
Subdivision Name: PINE O RAMA SUBD			Lot #: 1	Block #:
Latitude / Longitude in Decimal Degree (DD): 44.06262 °N -89.10129 °W				Method Code: GPS008
NE / SW or Govt Lot #:	Section: 5	Township: 18 N	Range: 12 E	

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	180

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S			SAND	Surface	42
	Y			SAND W GRAVEL	42	87
	S			SAND	87	123
	X		U	MUDDY SAND W CLAY	123	158
	C			CLAY	158	172
A	Y			COARSE SAND @ GRAVEL	172	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE NEW STEEL DRILLERS PIPE #18 97 ASTM A 53SAWHILL INDUSTRY	Surface	176
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	X4X12 SLOT STAINLESS STEEL	176	180

9. Static Water Level

93 ft. below ground surface

10. Pump Test

Pumping level 139 ft. below surface

Pumping at 25 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NA	Surface	0	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
		11-19-1908
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MAS		11-11-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		61

Type	Qualifier	Distance
Building Overhang		7
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-07-1999 Updated On: 08-17-2022 Review Status: