Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MS462

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PHELPS, LEROY @ LINDA	Phone #: (608)362-7243
Mailing Address: 916 LIBERTY AVE	
City: BELOIT	State: WI Zip Code: 53511
County: Rock	Co. Permit #:
Notification #	Completed: 09-28-1998
Well Constructor (Business Name): GOVERT BROS WELL DRILLING CO	Lic. #: 658
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 5234 N CO RD F JANESVILLE WI 53545	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.7	

1. Well Location

Town of BELOIT

Fire # (if avail.)

Street Address or Road Name and Number: 2181 SHERLAND AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.4965 °N -89.069 °W	GCD013

SW SW or Govt Lot #	Section	Township	Range
	34	1 N	12 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	42
6	42	105

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	TOP SOIL	Surface	4
L	CLAY @ GRAVEL	4	25
L	LIMESTONE	25	80
N	SANDSTONE	80	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 SCH 40 PE STEEL NEW #18 97 SAWHILL	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PUMP @ TREMMY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	42	8 S

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 25 GP M for 1.5 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MG		09-29-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
FP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		92

Type	Qualifier	Distance
Building Overhang		16
Septic or Holding, or POWTS Tank		41

Comment:

Created On: 10-28-1998 Updated On: 12-09-2019 Review Status: