

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MS747		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHWEICH, HENRY						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 8056 WATKINS DR						Town of BAILEYS HARBOR						2061							
City CLAYTON						State MO		Zip Code 63105				Street Address or Road Name and Number RIDGES RD							
County		Co. Permit #		Notification #		Completed 11-05-1998		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) JORNS HARVEY @ DAVID WELL DRLG I				Lic. # 68		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0712 °N -87.105 °W				Method Code GCD013					
Address 5235 BLUFF CT STURGEON BAY WI 54235-9790				Well Plan Approval #				SE SW		Section 16		Township 30 N		Range 28 E					
				Approval Date (mm-dd-yyyy)				or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type New Well									
Reason for replaced or reconstructed well ?																			
3. Well serves 1 # of HOME				Hicap Well ? No				Construction Type Drilled											
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock																
10 Surface 61			Yes Rotary - Mud Circulation																
8 61 171			Yes Rotary - Air																
6 171 241			Rotary - Air & Foam																
			Drill-Through Casing Hammer																
			Reverse Rotary																
			Cable-tool Bit ___ in. dia...																
			Dual Rotary																
			Yes Temp. Outer Casing 8in. dia																
			Yes Removed? ___ depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		6 ft. below ground surface				12 in. above grade					
6		STANDARD WEIGHT BLACK STEEL CASING NEW PLAIN ENDSAWHILL STEEL CO WT PER FT 18 97 ASTM A53				Surface		171		10. Pump Test				Developed ? Yes					
										Pumping level 174 ft. below surface				Disinfected ? Yes					
										Pumping at 14 GP M for 1 Hrs.				Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method BRAIDEN HEAD																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes					
NEAT CEMENT				Surface		171		54 S											
13. Constructor / Supervisory Driller										Lic #		Date Signed							
HJ												11-05-1998							
Drill Rig Operator										Lic or Reg #		Date Signed							
HJ																			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-07-1999

Updated On: 12-03-2019

Review Status: