

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MS966		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KROMSCHROEDER, JASON Phone # (651)467-5930						1. Well Location				Fire # (if avail.)	
Mailing Address 9406 INVERGROVE TRL						Town of GLENWOOD					
City INVER GROVE HEIGHTS State MN Zip Code 55076						Street Address or Road Name and Number 130TH AVE					
County St. Croix		Co. Permit #		Notification #		Completed 10-16-2000		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) THOMAS C FISHER				Lic. # 293		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code	
Address N324 CTY RD D EAU GALLE WI 54737-9500				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 29 30 N 15 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3		of previous unique well # constructed in			
3. Well serves 1 # of Private,potable				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?			
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		200							
						Rotary - Mud Circulation					
						Rotary - Air					
						Rotary - Air & Foam					
						Drill-Through Casing Hammer					
						Reverse Rotary					
						Cable-tool Bit ___ in. dia...					
						Dual Rotary					
						Temp. Outer Casing ___ in. dia					
						Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
I		TOPSOIL				Surface		3			
Y M		SILTY SAND & GRAVEL				3		42			
Z		GRAVEL & CLAY				42		75			
G H		GRAY SHALE				75		85			
T H		BROWN SHALE				85		95			
T N		BROWN SANDSTONE				95		200			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		IPSO ASTM A53B WELDED JOINTS				Surface		80			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method GRAVITY FED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
MAND BENTONITE		Surface				1 S					
9. Static Water Level											
155 ft. below ground surface											
10. Pump Test											
Pumping level 185 ft. below surface											
Pumping at 10 GP M for 2 Hrs.											
Pumping Method ?											
11. Well Is											
14 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed?											
13. Constructor / Supervisory Driller											
JDS		Lic #		Date Signed							
				10-18-2000							
Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-28-2000

Updated On: 11-28-2000

Review Status: