Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MS966

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KROMSCHROEDER, JASON	Phone #: (651)467-5930
Mailing Address: 9406 INVERGROVE TRL	
City: INVER GROVE HEIGHTS	State: MN — Zip Code: 55076
County: St. Croix	Co. Permit #: — Notification #: — Completed: 10-16-2000

1. Well Location

Town of GLENWOOD

Fire # (if avail.):

Street Address or Road Name and Number: 130TH AVE

Subdivision Name: — Lot #: — Block #:

Well Constructor (Business Name): THOMAS C FISHER	Lic. #: 293	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
Address: N324 CTY RD D EAU GALLE WI 54737-9500		Well Plan Approval #:	SW SW or Govt Lot #:	Section: 29 — Township: 30 N — Range: 15 W
		Approval Date (mm-dd-yyyy):		
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3		

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	200

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	3
		Y	M	SILTY SAND & GRAVEL	3	42
		Z		GRAVEL & CLAY	42	75
G		H		GRAY SHALE	75	85
T		H		BROWN SHALE	85	95
T		N		BROWN SANDSTONE	95	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53B WELDED JOINTS	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

155 ft. below ground surface

10. Pump Test

Pumping level 185 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MAND BENTONITE	Surface		1 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDS		10-18-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-28-2000 Updated On: 11-28-2000 Review Status: