Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MS972

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER, MARVIN			Phone #
Mailing Address: W493 ALBANY D			
City: MONDOVI	State: WI	Zip Code: 54755	
County: Pepin	Co. Permit #	Notification #	Completed: 10-17-2000

Well Constructor (Business Name): THOMAS C FISHER	Lic. #: 293	Facility ID # (Public Wells)	
Address: N324 CTY RD D EAU GALLE WI 54737-9500		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8	

3. Well serves 2 # of SAWMILL
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ALBANY

Fire # (if avail.)

Street Address or Road Name and Number: ALBANY D

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
NW NE or Govt Lot #	Section: 2	Township: 25 N	Range: 11 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
DRIVE POINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	2
		S		SAND	2	25
		Y		GRAVEL & SAND	25.25	28
	S	N		SOFT SANDSTONE	28	31
T		N		BROWN SANDSTONE	31	51
E		N		LIGHT GREEN SANDSTONE	51	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53B WELDED JOINTS	Surface	31
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GRAVITY FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MOUND BENTONITE	Surface		1 S

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 28 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
OWNER TO ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDS		10-26-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Drain - Sanitary	>	50
Building Overhang	>	50
Sewer - Building Sanitary	>	50
Animal Barn Pen	>	100
Animal Yard - Include Hutches	>	100
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 11-28-2000 Updated On: 11-28-2000 Review Status: