

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MS972		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MILLER, MARVIN						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W493 ALBANY D						Town of ALBANY									
City MONDOVI						State WI		Zip Code 54755				Street Address or Road Name and Number ALBANY D			
County		Co. Permit #		Notification #		Completed 10-17-2000		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) THOMAS C FISHER						Lic. # 293		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W					
Address N324 CTY RD D EAU GALLE WI 54737-9500						Well Plan Approval #		NW NE		Section 2		Township 25 N		Range 11 W	
								or Govt Lot #							
Approval Date (mm-dd-yyyy)						2. Well Type Replacement									
Hicap Permanent Well #						Common Well #		Specific Capacity 0.8		of previous unique well #				constructed in	
Reason for replaced or reconstructed well ? DRIVE POINT															
3. Well serves 2 # of SAWMILL Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		60		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
I				TOPSOIL				Surface		2					
S				SAND				2		25					
Y				GRAVEL & SAND				25.25		28					
S N				SOFT SANDSTONE				28		31					
T N				BROWN SANDSTONE				31		51					
E N				LIGHT GREEN SANDSTONE				51		60					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		IPSCO ASTM A53B WELDED JOINTS				Surface		31							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method GRAVITY FED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
MOUND BENTONITE				Surface				1 S							
9. Static Water Level															
16 ft. below ground surface															
10. Pump Test															
Pumping level 28 ft. below surface															
Pumping at 10 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
OWNER TO ABANDON															
13. Constructor / Supervisory Driller															
JDS				Lic #		Date Signed									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Sewer - Building Sanitary	>	50
Building Drain - Sanitary	>	50	Animal Barn Pen	>	100
Building Overhang	>	50	Animal Yard - Include Hutches	>	100
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 11-28-2000

Updated On: 11-28-2000

Review Status: