

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MS975		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner RATHBURN, JOHN						Phone # (715)723-9313		1. Well Location				Fire # (if avail.)		
Mailing Address N1399 810TH ST						Town of ROCK CREEK						Street Address or Road Name and Number		
City MONDOVI						State WI		Zip Code 54755		810TH ST				
County Dunn		Co. Permit #		Notification #		Completed 10-24-2000		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) THOMAS C FISHER				Lic. # 293		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address N324 CTY RD D EAU GALLE WI 54737-9500				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 20 26 N 11 W		2. Well Type New Well						
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ?						
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		50										
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
		SAND & GRAVEL				Surface		50						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		IPSCO ASTM A53B WELDED JOINTS				Surface		46						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		SS 18 SLOT US FILTER				46		50						
7. Grout or Other Sealing Material														
Method GRAVITY FED														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
MOUND BENTONITE		Surface				1 S								
9. Static Water Level														
22 ft. below ground surface														
10. Pump Test														
Pumping level 40 ft. below surface														
Pumping at 10 GP M for 2 Hrs.														
Pumping Method ?														
11. Well Is														
14 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? N/A														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
JDS								10-26-2000						
Drill Rig Operator						Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang	>	10
Building Drain - Sanitary	>	25	Sewer - Building Sanitary	>	25
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 11-28-2000

Updated On: 11-28-2000

Review Status: