Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MT161

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KINSMAN, PHILIP	Phone #: (608)727-2304
Mailing Address: S4681 HWY G	
City: LA VALLE	State: WI Zip Code: 53941
County: Sauk	Co. Permit #:
Notification #	Completed: 08-19-1998
Well Constructor (Business Name): BILL VAN DE YACHT	Lic. #: 37
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 3671 MONROE RD, DE PERE WI 54115-9711	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.4	

1. Well Location

Town of WESTFIELD

Fire # (if avail.)

Street Address or Road Name and Number: S6289 ELI VALLEY RD

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code
SW SW or Govt Lot #	Section: 30	Township: 11 N	Range: 4 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.75	Surface	61
6	61	142

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	CLAY @ GRAVEL	Surface	14
L	LIMEROCK	14	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD BLK PIPE 280 WALL WLD JTS A53 SAWHILL	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

80 ft. below ground surface

10. Pump Test

Pumping level 126 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	61	19 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
SVJ		09-01-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MS		09-01-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-04-1999 Updated On: 03-04-1999 Review Status: