Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MT415

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOFF, CLARICE	Phone #: (715)532-5648
Mailing Address: W8546 TANKER RD	
City: LADYSMITH	State: WI Zip Code: 54848
County: Rusk	Co. Permit #:
Notification #:	Completed: 02-13-1999
Well Constructor (Business Name): LARRY L WILLMARTH	Lic. #: 241
Facility ID # (Public Wells):	
Address: RT 3 BOX 132 HOLCOMBE WI 54745-9739	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.3	

1. Well Location

Town of FLAMBEAU	Fire # (if avail.): W8546
Street Address or Road Name and Number: W8546 TANKER RD	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.4739 °N -91.1138 °W	Method Code: GCD013

SE	NE	Section	Township	Range
or Govt Lot #		33	35 N	6 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: REPLACE 4 WELL IN BASEMEN

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	20
6	20	53

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	P	C	ROCKY HARD PAN NC BROWN HARD	Surface	30
	Q	S	U	DIRTY SAND CAVING BROWN SOFT	30	45
	Q	S		CLEAN SAND CAVING BROWN SOFT	45	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD ERW A53 97 GR B BLACK PE PIPE 6625ODX280 WALL	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	JOHNSON STAINLESS 15	49	53

7. Grout or Other Sealing Material

Method BACK FILL

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	20	

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 41 ft. below surface

Pumping at 10 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

HOME OWNER

13. Constructor / Supervisory Driller	Lic #	Date Signed
LW		02-19-1999
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Overhang	>	10

Type	Qualifier	Distance
Landfill	>	1200
Sewer - Building Sanitary	>	25
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 04-15-1999 Updated On: 06-24-2020 Review Status: