

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MT455		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner CROKER, MASON						Phone #															
Mailing Address PO BOX 218						1. Well Location						Fire # (if avail.)									
City PINE RIVER						State WI		Zip Code 54965				Town of WAUTOMA		W8265							
County Waushara						Co. Permit #		Notification #				Completed 10-26-1998		Street Address or Road Name and Number							
Well Constructor (Business Name) FARAGO PLBG @ TRENCHING INC						Lic. # 126		Facility ID # (Public Wells)				Subdivision Name		Lot #		Block #					
Address 606 W POPLAR ST PLAINFIELD WI 54966-9620						Well Plan Approval #		Latitude / Longitude in Decimal Degree (DD) 44.15547 °N -89.29565 °W				Method Code GPS008									
Heat Exchange ___ # of drillholes						Approval Date (mm-dd-yyyy)		NW NE		Section 3		Township 19 N		Range 10 E							
Hicap Permanent Well #						Common Well #		Specific Capacity 5				2. Well Type New Well									
3. Well serves 1 # of Private, potable						Hicap Well ? No		or Govt Lot #				of previous unique well # constructed in									
Heat Exchange ___ # of drillholes						Hicap Property ? No		Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		156										X		CLAY SAND		Surface		31	
						Rotary - Mud Circulation								S		SAND		31		89	
						Rotary - Air								Y		SAND GRAAVEL		89		126	
						Rotary - Air & Foam															
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		90 ft. below ground surface				624 in. above grade							
6		ISPCO 6 625 X 280 WALL WELD TOGETHER TOTAL WEIGHT 2902				Surface		153		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 93 ft. below surface				Disinfected ? Yes							
6		#12 JOHNSON K PACKER				153		156		Pumping at 15 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ?							
Method														12. Notified Owner of need to fill & seal ?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
#8 BENT ALONG CASING				Surface		0															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TPF				10-31-1998			
														Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		12
			Septic or Holding, or POWTS Tank		54

Comment:

Created On: 01-19-1999

Updated On: 08-23-2022

Review Status: