

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MT744		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WEIGLE, ROGER						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1435 EDGEWATER								Town of BEYENT							
City ROSHOLT						State WI		Zip Code 54473							
County Marathon		Co. Permit #		Notification #		Completed 10-07-1998		Subdivision Name BIG BASS LK				Lot # Block #			
Well Constructor (Business Name) BERTRAM JUNEMANN WELL DRILLING I				Lic. # 84		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7191 °N -89.4321 °W				Method Code GCD013	
Address 7285 CTY TRK S RUDOLPH WI 54475				Well Plan Approval #		NW SE		Section 20		Township 26 N		Range 9 E		or Govt Lot #	
Hicap Permanent Well #				Common Well #		Specific Capacity 5.7				2. Well Type New Well of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? NEW CONST									
3. Well serves 1 # of HOME Private, potable						Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		28		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
		SAND @ GRAVEL						Surface		28					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		PE A53 280 SAWHILL				Surface		25							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		TELE JOHNSON SS 15 SLOT				25		28							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
BENTONITE		Surface		0		1 S									
9. Static Water Level															
10.5 ft. below ground surface															
10. Pump Test															
Pumping level 14 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?															
11. Well Is															
16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? NONE															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
JJ								10-20-1998							
Drill Rig Operator						Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Shoreline/Pool		240

Comment:

Created On: 01-19-1999

Updated On: 05-11-2020

Review Status: