Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MT746

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GREG ALSZEWSKI CONST			Phone #
Mailing Address: 3656 GRAY LOG LN			
City: STEVENS POINT	State: WI	Zip Code: 54481	
County: Portage	Co. Permit #	Notification #	Completed: 10-09-1998

Well Constructor (Business Name): BERTRAM JUNEMANN WELL DRILLING I	Lic. #: 84	Facility ID # (Public Wells)	
Address: 7285 CTY TRK S RUDOLPH WI 54475		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 10	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of STOCKTON

Fire # (if avail.)

Street Address or Road Name and Number: 4256 OAKRIDGE CT

Subdivision Name	Lot #: 2	Block #

Latitude / Longitude in Decimal Degree (DD): 44.4643 °N -89.4409 °W				Method Code: GCD013
NE NW or Govt Lot #	Section: 20	Township: 23 N	Range: 9 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW CONST

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	99

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE A53 280 SAWHILL	Surface	96
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELE JOHNSON SS 12 SLOT	96	99

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	6 S

9. Static Water Level
64 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJ		10-14-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		85

Comment:

Created On: 01-19-1999 Updated On: 05-07-2020 Review Status: