

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MT748		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner S K CONST						Phone #						
Mailing Address 4311 WHITE PINE CIR						Town of GRAND RAPIDS						
City WISCONSIN RAPIDS						State WI		Zip Code 54494				
County Wood		Co. Permit #		Notification #		Completed 10-12-1998		Subdivision Name OAK RIDGE ESTS			Lot # 3	
Well Constructor (Business Name) BERTRAM JUNEMANN WELL DRILLING I				Lic. # 84		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.3611 °N -89.7499 °W			Method Code GCD013	
Address 7285 CTY TRK S RUDOLPH WI 54475				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 26 22 N 6 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 5		Reason for replaced or reconstructed well ? NEW CONST				
3. Well serves 1 # of HOMES				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Drilled		
Heat Exchange ___ # of drillholes				Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
6		Surface		42								
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
		SAND @ GRAVEL				Surface		42				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
6		PE A53 280 SAWHILL				Surface		39				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
6		TELE JOHNSON SS 15 SLOT				39		42				
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement						
BENTONITE		Surface		0		1 S						
9. Static Water Level												
21 ft. below ground surface												
10. Pump Test												
Pumping level 24 ft. below surface												
Pumping at 15 GP M for 1 Hrs.												
Pumping Method ?												
11. Well Is												
14 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ?												
Filled & Sealed Well(s) as needed? NONE												
13. Constructor / Supervisory Driller						Lic #		Date Signed				
JJ								10-13-1998				
Drill Rig Operator						Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Wastewater Sump		85
Building Overhang		5	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 01-07-1999

Updated On: 05-05-2020

Review Status: