Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MT750

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STENERSON, RICHARD	Phone #
Mailing Address: CAPE VISTA LOT 13	
City: WISCONSIN RAPIDS	State: WI — Zip Code: 54494
County: Wood	Co. Permit #: — Notification #: — Completed: 10-13-1998
Well Constructor (Business Name): BERTRAM JUNEMANN WELL DRILLING I	Lic. #: 84 — Facility ID # (Public Wells):
Address: 7285 CTY TRK S, RUDOLPH WI 54475	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.):

Street Address or Road Name and Number: CAPE VISTA

Subdivision Name: — Lot #: 13 — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW NE or Govt Lot #: — Section: 27 — Township: 22 N — Range: 6 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW CONST

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE A53 280 SAWHILL	Surface	41
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	TELE JOHNSON SS 12 SLOT	41	44

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 632 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

13 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	1 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJ		10-19-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52

Type	Qualifier	Distance
Building Overhang		6
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-19-1999 Updated On: 10-15-2026 Review Status: