Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MU023

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHAFFER, WALLY	Phone #: (920)923-1033
Mailing Address: W6255 NORTHWESTERN A	
City: FOND DU LAC	State: WI — Zip Code: 54935
County: Fond du Lac	Co. Permit #: — Notification #: — Completed: 09-24-1998
Well Constructor (Business Name): WAGNER BROTHERS WELL DRILLING IN	Lic. #: 654 — Facility ID # (Public Wells):
Address: W2282 HWY 149 MT CALVARY WI 53057-9720	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of FRIENDSHIP				Fire # (if avail.): W6255
Street Address or Road Name and Number: W6255 NORTHWESTERN AVE				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.81798 °N -88.47133 °W				Method Code: GPS008
SW NE or Govt Lot #:	Section: 33	Township: 16 N	Range: 17 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	42
6	42	222

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		RED CLAY	Surface	26
G		C	G	GRAY CLAY @ GRAVEL	26	30
		L		LIMESTONE	30	208
		N		SANDSTONE	208	222

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE 18 97 STEEL ASTMA53 280 WALL SAWHILL	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
99 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PUMPED BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	42	13 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CUW		09-24-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Collector Sewer - San or Storm		80
			Sewer - Building Sanitary		30

Comment:

Created On: 11-18-1998 Updated On: 08-23-2022 Review Status: