

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MU024		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner STEINBRENNER, BILL						Phone # (920)922-7527		1. Well Location				Fire # (if avail.)							
Mailing Address N4982 RIVER RD						Town of FOND DU LAC						N4982							
City FOND DU LAC						State WI		Zip Code 54935				Street Address or Road Name and Number N4982 RIVER RD							
County Fond du Lac		Co. Permit #		Notification #		Completed 09-24-1998		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) WAGNER BROTHERS WELL DRILLING IN				Lic. # 654		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7209 °N -88.495 °W				Method Code GCD013					
Address W2282 HWY 149 MT CALVARY WI 53057-9720				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 32 15 N 17 E				2. Well Type Replacement									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		Reason for replaced or reconstructed well ? LACK OF WATER													
3. Well serves 1 # of HOMES				Hicap Well ? No		Construction Type Drilled													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		255		Rotary - Mud Circulation				R C		RED CLAY		Surface		25			
						<u>Yes</u> Rotary - Air				G C C		GRAY CLAY @ STONES		25		103			
						Rotary - Air & Foam				H		SHALE		103		142			
						Drill-Through Casing Hammer				L		LIMESTONE		142		255			
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		85 ft. below ground surface				12 in. above grade					
6		NEW P E 18 97 STEEL ASTM A53 280 WALL SAWHILL				Surface		103		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 95 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
BENTONITE CRUMBLES				Surface		0		2 S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												CUW						09-24-1998	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												GM						09-24-1998	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		15
			Septic or Holding, or POWTS Tank		90

Comment:

Created On: 11-02-1998

Updated On: 10-08-2019

Review Status: