Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MU027

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLEINHANS CONSTRUCTION	Phone #: (920)893-5054
Mailing Address: PO BOX 53	
City: PLYMOUTH	State: WI Zip Code: 53073
County: Sheboygan	Co. Permit #:	Notification #:	Completed: 09-28-1998
Well Constructor (Business Name): WAGNER BROTHERS WELL DRILLING IN	Lic. #: 654	Facility ID # (Public Wells):
Address: W2282 HWY 149 MT CALVARY WI 53057-9720	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.7

1. Well Location

Town of RHINE				Fire # (if avail.): 7393
Street Address or Road Name and Number: 7393 RACETRACK RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8074 °N -87.99 °W				Method Code: GCD013
SW SE or Govt Lot #:		Section: 33	Township: 16 N	Range: 21 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	110

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	GRAVEL @ CLAY	Surface	75
X	CLAY @ SAND	75	105
G	GRAVEL	105	110

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE 18 97 STEEL ASTMA53 280 WALL SAWHILL	Surface	110
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
58 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	0	3 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CUW		09-28-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
GM		09-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120

Type	Qualifier	Distance
Building Overhang		17
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 11-18-1998 Updated On: 10-09-2019 Review Status: