

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MU027		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KLEINHANS CONSTRUCTION						Phone # (920)893-5054		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 53						Town of RHINE						7393	
City PLYMOUTH						State WI		Zip Code 53073				Street Address or Road Name and Number	
County Sheboygan						Co. Permit #		Notification #		Completed 09-28-1998		7393 RACETRACK RD	
Subdivision Name						Lot #		Block #					
Well Constructor (Business Name) WAGNER BROTHERS WELL DRILLING IN						Lic. # 654		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.8074 °N -87.99 °W		Method Code GCD013	
Address W2282 HWY 149 MT CALVARY WI 53057-9720						Well Plan Approval #		SW SE		Section 33		Township 16 N	
Hicap Permanent Well #						Common Well #		Specific Capacity 1.7		Range 21 E		2. Well Type New Well	
3. Well serves 1 # of HOME						Hicap Well ? No		or Govt Lot #		Reason for replaced or reconstructed well ?		of previous unique well # constructed in	
Private, potable						Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ?		Construction Type Drilled	
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		110		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Z		GRAVEL @ CLAY				Surface		75					
X		CLAY @ SAND				75		105					
G		GRAVEL				105		110					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW PE 18 97 STEEL ASTMA53 280 WALL SAWHILL				Surface		110					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE CRUMBLES		Surface		0		3 S							
9. Static Water Level													
58 ft. below ground surface													
10. Pump Test													
Pumping level 70 ft. below surface													
Pumping at 20 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
CUW		09-28-1998											
Drill Rig Operator		Lic or Reg #		Date Signed									
GM		09-28-1998											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Building Overhang		17
			Septic or Holding, or POWTS Tank		100

Comment:

Created On: 11-18-1998

Updated On: 10-09-2019

Review Status: