

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MU029		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SIPPEL, HAUEAND						Phone # (920)526-0741		1. Well Location				Fire # (if avail.)			
Mailing Address N7342 SCHOOL RD						Town of GREENBUSH						N7816			
City GLENBEULAH						State WI		Zip Code 53023				Street Address or Road Name and Number N7846 HULLS CROSSING DR			
County Sheboygan		Co. Permit #		Notification #		Completed 09-29-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) WAGNER BROTHERS WELL DRILLING IN				Lic. # 654		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8198 °N -88.1201 °W				Method Code GCD013	
Address W2282 HWY 149 MT CALVARY WI 53057-9720				Well Plan Approval #				NW NW		Section 33		Township 16 N		Range 20 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7				2. Well Type New Well					
Reason for replaced or reconstructed well ?															
3. Well serves 1 # of HOME				Hicap Well ? No				Construction Type Drilled							
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		265											
						Rotary - Mud Circulation									
						<u>Yes</u> Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C G				CLAY @ STONES				Surface		56					
L				LIMESTONE				56		265					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW ASTM A53 280 WALL SAWHILL 18 97 PPF PE				Surface		56							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE CRUMBLES				Surface		0		3 S							
9. Static Water Level															
30 ft. below ground surface															
10. Pump Test															
Pumping level 45 ft. below surface															
Pumping at 10 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
CUW				10-05-1998											
Drill Rig Operator				Lic or Reg #				Date Signed							
GPM				09-30-1998											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		20
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 11-18-1998

Updated On: 10-09-2019

Review Status: