Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MU806

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LUTZOW, ALLEN	Phone #: (715)489-3397
Mailing Address: W14573 PARK AVE	
City: MATTOON	State: WI — Zip Code: 54450
County: Shawano	Co. Permit #:	Notification #:	Completed: 08-20-1998
Well Constructor (Business Name): DANIEL DILLENBURG	Lic. #: 196	Facility ID # (Public Wells):
Address: W9618 ANGLE RD SHAWANO WI 54166	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0

1. Well Location

Town of HUTCHINS

Fire # (if avail.):

Street Address or Road Name and Number: W14573 PARK AVE

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.9983 °N -88.9842 °W

Method Code: GCD013

NE	NE	Section	Township	Range
or Govt Lot #		13	29 N	12 E

2. Well Type Replacement

of previous unique well # EJ716 constructed in 91

Reason for replaced or reconstructed well ?

LOW YIELD

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	185

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Y		CAVING SAND @ GRAVEL	Surface	40
		Z		GRAVEL @ CLAY	40	74
		Q		GRANITE	74	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL A53B 19 45# FT 280 WELDED SAWHILL	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

47 ft. below ground surface

10. Pump Test

Pumping level 175 ft. below surface

Pumping at 2 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
PK		09-28-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Sewer - Building Sanitary		35
Building Overhang		14	Septic or Holding, or POWTS Tank		110

Comment:

Created On: 10-20-1998 Updated On: 10-15-2026 Review Status: