

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MV291		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MANN, MIKE & LEEANN						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 5178 S 46TH ST								Town of LISBON													
City GREENFIELD						State WI		Zip Code 53220													
County Waukesha		Co. Permit #		Notification #		Completed 11-29-1999		Subdivision Name RICHMOND HTS				Lot # 3									
Well Constructor (Business Name) PATRICK J LAHR				Lic. # 187		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.1184 °N -88.2703 °W				Method Code GCD013									
Address N48 W14784 LISBON RD MENOMONEE FALLS WI 53051				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE		Section 32		Township 8 N									
								Range 19 E													
Hicap Permanent Well #		Common Well #		Specific Capacity 2.4		2. Well Type New Well		of previous unique well # constructed in													
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ? NEW HOME													
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		45		Rotary - Mud Circulation						C G		CLAY & STONES		Surface		28			
6		45		184		<u>Yes</u> Rotary - Air						L		LIMESTONE		28		184			
						Rotary - Air & Foam															
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						<u>Yes</u> Temp. Outer Casing 8in. dia															
						<u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		115 ft. below ground surface				12 in. above grade							
6		P.E PIPE ASTM A-53 GR. B SAWHILL TUB., 18.97#/FT WELDED				Surface		45		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 140 ft. below surface				Disinfected ? Yes							
										Pumping at 60 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method TREMIE PIPE														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		NONE													
PURE PORTLAND		Surface		45		9 S															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														PJL						12-02-1999	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Foundation Drain to Clearwater		45
Building Drain - Sanitary		40	Sewer - Building Sanitary		40
Building Overhang		19	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-25-2000

Updated On: 07-12-2019

Review Status: