Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MV291

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MANN, MIKE & LEEANN			Phone #
Mailing Address: 5178 S 46TH ST			
City: GREENFIELD	State: WI	Zip Code: 53220	
County: Waukesha	Co. Permit #	Notification #	Completed: 11-29-1999

Well Constructor (Business Name): PATRICK J LAHR	Lic. #: 187	Facility ID # (Public Wells)	
Address: N48 W14784 LISBON RD MENOMONEE FALLS WI 53051		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LISBON

Fire # (if avail.)

Street Address or Road Name and Number: W262 N5533 BODEN LN

Subdivision Name	Lot #	Block #
RICHMOND HTS	3	

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.1184 °N	-88.2703 °W			GCD013
NE NE or Govt Lot #	Section: 32	Township: 8 N	Range: 19 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	45
6	45	184

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 8in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY & STONES	Surface	28
		L		LIMESTONE	28	184

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E PIPE ASTM A-53 GR. B SAWHILL TUB., 18.97#/FT WELDED	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PURE PORTLAND	Surface	45	9 S

9. Static Water Level
115 ft. below ground surface

10. Pump Test
Pumping level 140 ft. below surface
Pumping at 60 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
PJL		12-02-1999
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Drain - Sanitary		40
Building Overhang		19

Type	Qualifier	Distance
Foundation Drain to Clearwater		45
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-25-2000 Updated On: 07-12-2019 Review Status: