

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MV293		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LAYMAN, BRAD						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 4030 MEACHEM RD						City of FRANKLIN						Street Address or Road Name and Number 4046 W PUETZ RD					
City RACINE				State WI		Zip Code 53403											
County Milwaukee		Co. Permit #		Notification #		Completed 12-14-1999		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) PATRICK J LAHR				Lic. # 187		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8876 °N -87.9687 °W			Method Code GCD013				
Address N48 W14784 LISBON RD MENOMONEE FALLS WI 53051				Well Plan Approval #				SW SW Section Township Range or Govt Lot # 13 5 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME							
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 1				Construction Type Drilled									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method								8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C CLAY X SAND & CLAY C G CLAY & STONES P HARDPAN L LIMESTONE		Surface 80 80 110 110 155 155 165 165 178							
6. Casing, Liner, Screen								9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				12 in. above grade			
6		P/E PIPE ASTMA-53 GR.B SAWHILL TUB., 18.97# FT. WELDED				Surface		165		10. Pump Test Pumping level 140 ft. below surface Pumping at 60 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method MOUND								12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE									
Kind of Sealing Material				From (ft.)		To (ft.)										# Sacks Cement	
CLAY SLURRY & BENTONITE				Surface		20											
								13. Constructor / Supervisory Driller				Lic #		Date Signed			
								PJJ						12-15-1999			
								Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		35	Downspout/Yard Hydrant		20
Building Overhang		18	Foundation Drain to Sewer		30
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		45

Comment:

Created On: 01-25-2000

Updated On: 09-26-2019

Review Status: