Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MV294

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TZOUGROS, JOSEPH & HELEN			Phone #
Mailing Address: S47 W33732 FOX HOLLO			
City: GENESEE	State: WI	Zip Code: 53118	
County: Waukesha	Co. Permit #	Notification #	Completed: 01-07-2000

Well Constructor (Business Name): PATRICK J LAHR	Lic. #: 187	Facility ID # (Public Wells)
Address: N48 W14784 LISBON RD MENOMONEE FALLS WI 53051		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GENESEE

Fire # (if avail.)

Street Address or Road Name and Number: S47 W33732 FOX HOLLOW DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

NW NW or Govt Lot #	Section: 30	Township: 6 N	Range: 18 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	224

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	C	SAND, GRAVEL & CLAY	Surface	5
		G		GRAVEL	5	75
		P		HARD PAN	75	86
		L		LIMESTONE	86	224

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P/E PIPE ASTM A-53 GR. B SAWHILL TUB., 18.97#/FT. WELDED	Surface	86
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
94 ft. below ground surface

10. Pump Test
Pumping level 140 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS & BENTONITE CRU	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
PJL		01-10-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		12
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-01-2000 Updated On: 03-01-2000 Review Status: