Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MV335

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WARD, RON	Phone #: (715)634-7736
Mailing Address: 7216 N ST RD 77	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #: — Notification #: — Completed: 10-14-1998
Well Constructor (Business Name): BUTTERFIELD ROSCOE WELL @ PUMP I	Lic. #: 6102 — Facility ID # (Public Wells):
Address: RT 3 BOX 3047 HAYWARD WI 54843	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7.5

1. Well Location

Town of LENROOT

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW	SW	Section	Township	Range
or Govt Lot #		25	42 N	9 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	60

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z	G	GRAVEL CLAY ROCKS	Surface	17
	W	S		SAND WATER	17	20
	A	Z	G	GRAVEL CLAY COARSE GRAVEL	20	30
	A	Y	G	SAND GRAVEL ROCKS COARSE GRAVEL WATER	30	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL WELDED 10 79# FT ASTM A53B IPSCO	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL 18 SLOT	57	60

7. Grout or Other Sealing Material

Method MOUNDED AROUND PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 14 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RL		11-06-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		114

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		28

Comment:

Created On: 01-07-1999 Updated On: 01-07-1999 Review Status: