

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MV345		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner WIGGINS SCHRYVER, MICHAEL						Phone # (715)634-7944		1. Well Location				Fire # (if avail.)									
Mailing Address 7688 N COURT OREILLE						Town of SAND LAKE															
City HAYWARD						State WI		Zip Code 54843													
County Sawyer		Co. Permit #		Notification #		Completed 11-03-1998		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) BUTTERFIELD ROSCOE WELL @ PUMP I				Lic. # 6102		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 3 BOX 3047 HAYWARD WI 54843				Well Plan Approval #		SW SE		Section 12		Township 39 N		Range 9 W									
Hicap Permanent Well #				Common Well #		Specific Capacity 5		2. Well Type New Well													
						of previous unique well # constructed in															
						Reason for replaced or reconstructed well ?															
3. Well serves 1 # of Private, potable						Hicap Well ? No															
Heat Exchange ___ # of drillholes						Hicap Property ? No															
						Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
4		Surface		110								Z		GRAVEL CLAY		Surface		16			
						Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Y		SAND GRAVEL		16		25			
												Y		SAND GRAVEL WATER		25		38			
												S M		SAND SILT		38		80			
										W S		SAND WATER		80		110					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		27 ft. below ground surface				24 in. above grade							
4		NEW BLACK STEEL WELDED 10 79# FT ASTM A53B IPSCO				Surface		107		10. Pump Test Pumping level 30 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
4		STAINLESS STEEL 12 SLOT				107		110													
7. Grout or Other Sealing Material Method MOUNDED AROUND PIPE														12. Notified Owner of need to fill & seal ?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No NONE											
BENTONITE				Surface		0															
13. Constructor / Supervisory Driller														Lic #		Date Signed					
RL																11-11-1998					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		96	Building Overhang		12
			Septic or Holding, or POWTS Tank		84

Comment:

Created On: 11-24-1998

Updated On: 11-24-1998

Review Status: