Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MV553

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROTAR, ELIZABETH			Phone #: (608)278-8262
Mailing Address: 2952 RICHARDSON ST			
City: MADISON	State: WI	Zip Code: 53711	
County: Adams	Co. Permit #:	Notification #:	Completed: 09-23-1998

Well Constructor (Business Name): QUINNELLS SEPTIC @ WELL SERVICE	Lic. #: 97	Facility ID # (Public Wells):	
Address: 1894 DAKOTA AVE FRIENDSHIP WI 53934-9802		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of MONROE				Fire # (if avail.): 883
Street Address or Road Name and Number: 883 19TH DR				
Subdivision Name: PETENWELL PINES			Lot #: 75	Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1294 °N -89.9444 °W				Method Code: GCD013
SW SE or Govt Lot #:		Section: 7	Township: 19 N	Range: 5 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OLD WELL SLOW

Construction Type: Jetted

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	5
2	5	46

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	16
C	CLAY	16	19
S	SAND	19	36
G	GRAVEL	36	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	LACLEDE CORP ASTM A 589 IPS 154 WALL 3 75# FT T&C	Surface	42
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.5	4 CAMPBELL 60 GAUZE	42	46

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SAND	Surface	0	

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 12 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDQ		09-23-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Type	Qualifier	Distance
Building Overhang		14
Septic or Holding, or POWTS Tank		62

Comment:

Created On: 10-29-1998 Updated On: 05-04-2020 Review Status: