Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MV722

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TRYBA, DARREL		Phone #: (715)446-3378
Mailing Address: 2381 CTH Y		
City: HATLEY	State: WI	Zip Code: 54440

County	Co. Permit #	Notification #	Completed
Marathon			11-02-1998

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HAUPT WELL @ PUMP CO INC	529	

Address: 5508 MAIN ST
AUBURNDALE WI 54412

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of REID

Fire # (if avail.): 811

Street Address or Road Name and Number: 811 TRYBA RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.7974 °N	-89.4077 °W			GCD013

NE	NE	Section	Township	Range
or Govt Lot #		28	27 N	9 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	142

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z	S	SANDY CLAY @ BOULDERS	Surface	46
		Q		GRANITE	46	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18 97 A53 SAWHILL P E WELDED	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8	Surface	0	2 S

9. Static Water Level
33 ft. below ground surface

10. Pump Test
Pumping level 140 ft. below surface
Pumping at 2 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
30 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH		11-03-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AH		11-03-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		143	Building Overhang		46
			Septic or Holding, or POWTS Tank		105

Comment:

Created On: 01-15-1999 Updated On: 10-15-2026 Review Status: