Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MW065

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUDE, JAMES J			Phone #: (715)356-1465
Mailing Address: PO BOX 134			
City: MINOCQUA	State: WI	Zip Code: 54548	
County: Oneida	Co. Permit #:	Notification #:	Completed: 11-11-1998

1. Well Location

Town of MINOCQUA

Fire # (if avail.): 9283

Street Address or Road Name and Number: ELLENBEE LANE

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
NEHLS @ WEBSTER WELL DRILLING	6076	

Latitude / Longitude in Decimal Degree (DD): 45.8803 °N -89.6865 °W

Method Code: GCD013

Well Plan Approval #:

SE	SW	Section	Township	Range
or Govt Lot #		12	39 N	6 E

Address: 1901 APACHE LN
RHINELANDER WI 54501

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		CAVING SAND	Surface	20
		S		SAND	20	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE SAWHILL 18 97 A53	Surface	41
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	10 SLOT S S	41	44

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
PW		11-18-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BF		11-11-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		4
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 01-07-1999 Updated On: 06-30-2020 Review Status: