

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MW068		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GATTON, MARK					Phone # (414)744-7994		1. Well Location				Fire # (if avail.)			
Mailing Address 3016 S HORMAN ST							Town of SCHOEPEKE							
City MILWAUKEE							State WI		Zip Code 53207			Street Address or Road Name and Number HWY Q		
County Oneida		Co. Permit #		Notification #		Completed 11-16-1998		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) NEHLS @ WEBSTER WELL DRILLING				Lic. # 6076		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address 1901 APACHE LN RHINELANDER WI 54501				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NE Section Township Range or Govt Lot # 15 35 N 10 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ?						
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Drilled				
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		71		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)						
Q S			CAVING SAND			Surface		15						
Z			CLAY @ GRAVEL			15		69						
B Q			BROKEN GRANITE			69		71						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		PE SAWHILL 18 97 A53				Surface		71						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material Method														
9. Static Water Level 15 ft. below ground surface														
10. Pump Test Pumping level 65 ft. below surface Pumping at 4 GP M for 2 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
PW								11-18-1998						
Drill Rig Operator								Lic or Reg #		Date Signed				
BF								11-16-1998						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		10
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-07-1999

Updated On: 01-07-1999

Review Status: