Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MW068

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GATTON, MARK	Phone #: (414)744-7994
Mailing Address: 3016 S HORMAN ST	
City: MILWAUKEE	State: WI — Zip Code: 53207
County: Oneida	Co. Permit #:
Notification #	Completed: 11-16-1998
Well Constructor (Business Name): NEHLS @ WEBSTER WELL DRILLING	Lic. #: 6076
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 1901 APACHE LN RHINELANDER WI 54501	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.1	

1. Well Location

Town of SCHOEPKE

Fire # (if avail.)

Street Address or Road Name and Number: HWY Q

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NW	NE	Section	Township	Range
or Govt Lot #		15	35 N	10 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	71

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	S		CAVING SAND	Surface	15
	Z		CLAY @ GRAVEL	15	69
B	Q		BROKEN GRANITE	69	71

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE SAWHILL 18 97 A53	Surface	71
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 4 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
PW		11-18-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BF		11-16-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-07-1999 Updated On: 01-07-1999 Review Status: