Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MW328

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PESERL, THOMAS	Phone #: (414)691-1272
Mailing Address: 190 OVERLOOK CT	
City: PEWAUKEE	State: WI — Zip Code: 53072
County: Waukesha	Co. Permit #: — Notification #: — Completed: 10-26-1998
Well Constructor (Business Name): ROSCHI BROS WELL DRLG @ PUMP INC	Lic. #: 435 — Facility ID # (Public Wells):
Address: N10W28210 NORTHVIEW WAUKESHA WI 53188-9401	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of MERTON

Fire # (if avail.):

Street Address or Road Name and Number: W280 N5020 JERILANE CT

Subdivision Name	Lot #	Block #
MAES WALK	1	

Latitude / Longitude in Decimal Degree (DD): 43.1088 °N -88.3043 °W — Method Code: GCD013

SE or Govt Lot #	SE	Section: 36	Township: 8 N	Range: 18 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NEW CONSTRUCTION

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	213

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	STONEY CLAY	Surface	14
		P		HARDPAN	14	63
		L		LIMESTONE	63	210
		H		SHALE	210	213

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS 18 97# ASTMA53 1780PSI SAWHILL TUBULAR	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

47 ft. below ground surface

10. Pump Test

Pumping level 67 ft. below surface

Pumping at 16 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		10-26-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TDK		10-26-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Foundation Drain to Clearwater		15
			Septic or Holding, or POWTS Tank		98

Comment:

Created On: 11-24-1998 Updated On: 07-12-2019 Review Status: