

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MW329		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner ROZNIK, MARK						Phone # (414)367-5620		1. Well Location				Fire # (if avail.)		
Mailing Address W305 N 2768 FOXWOOD COURT						Town of DELAFIELD						W305		
City PEWAUKEE						State WI		Zip Code 53072				Street Address or Road Name and Number N2768 FOXWOOD COURT		
County Waukesha		Co. Permit #		Notification #		Completed 10-28-1998		Subdivision Name FOXWOOD ESTATES			Lot # 5		Block #	
Well Constructor (Business Name) ROSCI BROS WELL DRLG @ PUMP INC				Lic. # 435		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address N10W28210 NORTHVIEW WAUKESHA WI 53188-9401				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NW Section Township Range or Govt Lot # 15 7 N 18 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ? NEW CONSTRUCTION						
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes						Hicap Property ? No								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		279		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)				
	Y	SAND GRAVEL						Surface		12				
	P	HARDPAN						12		67				
	Y	SAND GRAVEL						67		119				
	P	HARDPAN						119		143				
	L	LIMESTONE						143		169				
	H	SHALE						169		173				
	L	LIMESTONE						173		181				
S	H	SOFT SHALE						181		185				
	L	LIMESTONE						185		195				
X	L	H	SHALE W/ STREAKS LIMESTONE						195		279			
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		BLACK STEEL PIPE WELDED JOINTS 18 97 LB ASTM A531780 PSI SAWHILL TUBULAR				Surface		143						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
BENTONITE CRUMBLES		Surface		25										

9. Static Water Level

141 ft. below ground surface

10. Pump Test

Pumping level 171 ft. below surface

Pumping at 20 GP M for 1.5 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller

Lic #

Date Signed

RB

10-28-1998

Drill Rig Operator

Lic or Reg #

Date Signed

TDK

10-28-1998

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		16	Collector Sewer - San or Storm	>	50
			Foundation Drain to Clearwater		15

Comment:

Created On: 01-11-1999

Updated On: 10-24-2002

Review Status: