Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: MW329

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROZNIK, MARK	Phone #: (414)367-5620
Mailing Address: W305 N 2768 FOXWOOD COURT	
City: PEWAUKEE	State: WI — Zip Code: 53072
County: Waukesha	Co. Permit #:
Notification #:	Completed: 10-28-1998
Well Constructor (Business Name): ROSCHI BROS WELL DRLG @ PUMP INC	Lic. #: 435
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: N10W28210 NORTHVIEW WAUKESHA WI 53188-9401	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of DELAFIELD	Fire # (if avail.): W305
Street Address or Road Name and Number: N2768 FOXWOOD COURT	
Subdivision Name: FOXWOOD ESTATES	Lot #: 5 — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:

NW	NW	Section	Township	Range
or Govt Lot #		15	7 N	18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW CONSTRUCTION

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	279

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND GRAVEL	Surface	12
		P		HARDPAN	12	67
		Y		SAND GRAVEL	67	119
		P		HARDPAN	119	143
		L		LIMESTONE	143	169
		H		SHALE	169	173
		L		LIMESTONE	173	181
	S	H		SOFT SHALE	181	185
		L		LIMESTONE	185	195
	X	L	H	SHALE W/ STREAKS LIMESTONE	195	279

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS 18 97 LB ASTM A531780 PSI SAWHILL TUBULAR	Surface	143
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	25	

9. Static Water Level	11. Well Is
141 ft. below ground surface	14 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 171 ft. below surface	Disinfected ? Yes
Pumping at 20 GP M for 1.5 Hrs.	Capped ? Yes
Pumping Method ?	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		10-28-1998
Drill Rig Operator	Lic or Reg #	Date Signed
TDK		10-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		16	Collector Sewer - San or Storm	>	50
			Foundation Drain to Clearwater		15

Comment:

Created On: 01-11-1999 Updated On: 10-24-2002 Review Status: