Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MW330

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVID @ GOLIATH BLDR			Phone #: (414)691-8841
Mailing Address: PO BOX 23			
City: PEWAUKEE	State: WI	Zip Code: 53072-0023	
County: Racine	Co. Permit #:	Notification #:	Completed: 10-30-1998

1. Well Location

Town of WATERFORD

Fire # (if avail.):

Street Address or Road Name and Number: 28636 E RIVER BAY RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROSCHI BROS WELL DRLG @ PUMP INC	435	

Latitude / Longitude in Decimal Degree (DD): 42.8041 °N -88.2053 °W

Method Code: GCD013

NW SW or Govt Lot #	Section	Township	Range
	13	4 N	19 E

Address: N10W28210 NORTHVIEW
WAUKESHA WI 53188-9401

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.7

Reason for replaced or reconstructed well ?: NEW CONSTRUCTION

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	77

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	56
		C	G	STONEY CLAY	56	70
		Y		SAND GRAVEL	70	77

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS 18 97 LB ASTM A531780 PSI SAWHILL TUBULAR	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.75	JOHNSON STAINLESS 18	74	77

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 49 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	23	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		10-30-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TDK		10-30-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Collector Sewer - San or Storm	>	50
Clearwater Sump		60	Foundation Drain to Clearwater		8
			Sewer - Building Sanitary		12

Comment:

Created On: 01-07-1999 Updated On: 06-28-2019 Review Status: