

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MW330		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner DAVID @ GOLIATH BLDR						Phone # (414)691-8841		1. Well Location				Fire # (if avail.)											
Mailing Address PO BOX 23						Town of WATERFORD																	
City PEWAUKEE						State WI		Zip Code 53072-0023				Street Address or Road Name and Number 28636 E RIVER BAY RD											
County Racine		Co. Permit #		Notification #		Completed 10-30-1998		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) ROSCHI BROS WELL DRLG @ PUMP INC				Lic. # 435		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8041 °N -88.2053 °W				Method Code GCD013									
Address N10W28210 NORTHVIEW WAUKESHA WI 53188-9401				Well Plan Approval #				NW SW Section Township Range or Govt Lot # 13 4 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONSTRUCTION													
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #				Common Well #		Specific Capacity 1.7				Construction Type Drilled													
3. Well serves 1 # of Private, potable				Hicap Well ? No																			
Heat Exchange ___ # of drillholes				Hicap Property ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Surface		77		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						C		CLAY		Surface		56					
												C G		STONE CLAY		56		70					
												Y		SAND GRAVEL		70		77					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				12 in. above grade									
6		BLACK STEEL PIPE WELDED JOINTS 18 97 LB ASTM A531780 PSI SAWHILL TUBULAR				Surface		74		10. Pump Test Pumping level 49 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
5.75		JOHNSON STAINLESS 18				74		77															
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
BENTONITE CRUMBLES				Surface		23																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														RR						10-30-1998			
														Drill Rig Operator				Lic or Reg #		Date Signed			
														TDK						10-30-1998			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Collector Sewer - San or Storm	>	50
Clearwater Sump		60	Foundation Drain to Clearwater		8
			Sewer - Building Sanitary		12

Comment:

Created On: 01-07-1999

Updated On: 06-28-2019

Review Status: